



NOTES:  
 1. LUBRICATE CONTACT SURFACES  
 2. FOR CORRECT CONTACT PRESSURE ON CLIP, ADJUST BLADES SO THEY ARE .013 ±.004 WIDER IN THE CLOSED POSITION THAN IN THE OPEN POSITION. THIS DIM. MUST BE MEASURED IN THE OUTSIDE OF THE BLADES, ABOVE THE CONTACT POINTS.

-	-	-	-	16	-
-	-	-	-	15	-
-	-	-	-	14	-
-	-	-	-	13	-
4	4	4	-	12	DRIVE SCREW
12	12	12	-	11	MACHINE BOLT 1/2"-13 X 1 1/4" LW
1	1	1	MP251800X	10	NAMEPLATE
3	-	-	-	9	INSULATOR (TR208)
-	3	-	-	8	INSULATOR (TR205)
-	-	3	-	7	INSULATOR (TR202)
1	-	-	A009551	6	CURRENT CARRYING PARTS 23 KV
-	1	-	A009448	5	CURRENT CARRYING PARTS 15 KV
-	-	1	A009447	4	CURRENT CARRYING PARTS 7.5 KV
1	-	-	087521SAG	3	MOUNTING BASE 23 KV
-	1	-	087520SAG	2	MOUNTING BASE 15 KV
-	-	1	087519SAG	1	MOUNTING BASE 7.5 KV
QUANTITY	UNIT	MATERIAL	SIZE	DESCRIPTION	
TO:					
CUSTOMER P.O.#					
SERIAL NUMBER:					
REVISION	DATE	BY	CHK	REV	APP
REV BLADE INSTALL. BEN 3/76	11-7-66	BAR	A		
BT21-7, 15, 23-6 HOOKSTICK SWITCH					
TURNER ELECTRIC CORPORATION FAIRVIEW HEIGHTS, ILL., USA					
DRAWING # D84000-2					
SHEET 1 OF 1					