



- NOTES:
1. THE INSULATORS ARE SHOWN FOR HORIZONTAL AND VERTICAL MOUNTING
 2. THE INSULATORS ARE INVERTED FOR UNDER-HUNG MOUNTINGS
 3. FOR CORRECT CONTACT PRESSURE ON CLIP, ADJUST BLADES SO THEY ARE $.013 \pm .004$ " WIDER IN THE CLOSED POSITION THAN IN THE OPEN POSITION. THIS DIMENSION MUST BE MEASURED ON THE OUTSIDE OF THE BLADES, ABOVE CONTACT POINTS.
 4. LUBRICATE CONTACT SURFACES PER SPEC.
 5. STANDARD BASES ARE GALV STEEL.
 6. TINNED TERMINAL PADS (OPTIONAL)

QTY	QTY	MATERIAL	QTY	DESCRIPTION
8	-	GALV	10	FLAT WASHER 5/8"
-	-	-	9	-
16	-	GALV	8	MACHINE BOLT 5/8"-11 * 1 1/2" LW
4	-	-	7	DRIVE SCREW
1	MP251800X	ALUM	6	NAMEPLATE
2	011098SD0MG	GALV	5	5" TO 3" B.C. ADAPTER
4	-	GALV	4	MACHINE BOLT 1/2-13 * 2 1/2" LW,N
2	-	-	3	INSULATOR TR286
1	A009664/115	-	2	CURRENT CARRYING PARTS ASSY
1	011834SXG	GALV	1	MOUNTING BASE 115 KV

REV	DATE	BY	CHKD	DESCRIPTION
1	11-14-02	MP	A	115KV
2	12-30-02	MP	B	600 AMP

DRAWING # SK981022
 SHEET 1 OF 1

BT2-115-06/6014
 HOOKSTICK SWITCH
 TURNER ELECTRIC CORPORATION
 FAIRVIEW HEIGHTS, IL., USA